

Perkins&Will

PENDING DOCUMENT REVISIONS LOG

Belmont Middle and High School

6/6/2022

→ NEW ITEM SINCE LOG DATED 5/26/22

| PENDING REVISIONS | | | | |
|--|-----------|--------------------|--|---|
| ID | To Issue | OME | Subject | Description |
| ASI-033 | TBD | \$0 | POOL & FIELD HOUSE BANNER SYSTEM DETAILS | Clarifications to banner support system. |
| → ASI-244 | 6/10/2022 | \$0 | RADIANT FLOOR ZONE PROGRAMMING CLARIFICATIONS PER Cx | Also making programming changes to the radiant floor zones which are overshooting control of space temp. and are not synchronized with their respective zone VAV terminals. |
| PR-155 | 6/10/2022 | \$20,000 | PARAPET HANDRAIL AND TIE-OFFS FOR E111 ROOF | Providing handrail and roof tie-offs for E111 roof for maintenance access. Also includes removal of one ladder proposed in previously issued PR-128 AMENDED. |
| → CCD-435 <small>(DESCR. REVISED)</small> | 6/10/2022 | \$10,000 | POWER FOR DOOR OPERATORS IN PHASE 2, ELECTRONIC LOCKING SWITCH FOR DOORS F181A.1 & F181A.2 | CCD-435 will provide power for door XF100D.2 for automatic operator. Also adding remote locking switch for doors F181A.1 & F181A.2 |
| → CCD-437 <small>(DESCR. REVISED)</small> | TBD | (\$383,410) | PHASE 2 ATHLETIC FIELD & SITE REVISIONS | Revising scope of several landscape and site related items following School Building Committee direction. Includes addition of planting screen for electrical switch gear and proposed location for salvaged granite pedestal as part of the Brendent Grant Memorial. |
| CCD-440 | 6/10/2022 | \$2,500 | TEMP. SECURITY CAMERA FOR TEMP. LOCKER RM. LAYOUT | Adding security camera to Vestibule E112C to provide surveillance of construction access door at west side of E111. |
| CCD-442 | 6/10/2022 | \$0 | NEW LOCKERS IN LIEU OF SALVAGED FROM WHITE FIELD HOUSE | Providing new lockers in lieu of salvaging existing lockers from the White Field House. |
| CCD-443 | 6/10/2022 | \$10,000 | REMOVABLE HANDRAIL FOR ORCHESTRA PIT STAIR | Providing removable handrail for orchestra pit stair, and reverting to built-in stair in lieu of moveable, prefabricated stair. |
| Subtotal Pending Rev. | | (\$340,910) | | |

REVISIONS ISSUED LAST WEEK THAT WERE NOT SHOWN ON PREVIOUS LOGS:

| | | |
|---------|--|--|
| ASI-242 | LOUVER SIZE CLARIFICATION AT ALT. P.E. RM. E204 PER RFI 1651 | Matching louver size owned in mechanical drawings to architectural elevation. |
| ASI-243 | MECHANICAL PROGRAMMING CLARIFICATIONS PER Cx | Changing SOO for two chiller heater banks to provide more stable control of chilled water supply. |
| PR-157 | ADDED MIXING VALVE FOR GEOTHERMAL PIPING | Adding a mixing valve for geothermal piping to prevent condensation forming on pipes in mechanical shaft above custodial workshop. |
| CCD-445 | BOLLARDS AT PHASE 2 ELECTRICAL SWITCH GEAR | Provided bollard layout for P2 electrical switch gear per sketch Belmont Light provided. |